



Certificate of Conformity

1-2 Floor, South Block, Building A2,
No 3 Keyan Lu, Science City,
Guangzhou, China

Tel: 86-20-32209330
Fax: 86-20-62824387
www.i-testlab.com

No. ITL-13054519

The following products have been tested by us with the listed standards and found in compliance with the European directive 2006/95/EC. It is possible to use CE marking to demonstrate the compliance with the LVD directive.

Applicant : **Zhongshan Shangfang Instrument Meter Co., Ltd.**

Address : Rear Building No.5, Hubin North Road, Shiqi District,
Zhongshan, Guangdong 528400, China

Product name : **Digital Display Temperature Controller**

Model No. : **SF-XXX, EDXXX, PNXXX (X= numbers 0-9, indicates
different customers for marketing purpose only)**

Technical data : Input: 230V~ 50/60Hz 30mA
Lighting/Compressor/Defogging heater load: 5/30/10A 250Vac
50/60Hz; 100 000 cycles; Operation temperature: -10°C - 60°C

Test Report No. : 13054519

Test Standards

IEC 60730-2-9:2008 (Third Edition) in conjunction with
IEC 60730-1: 1999(Third Edition) + A1:2003+ A2:2007

EN 60730-2-9:2010 used in conjunction with
EN 60730-1:2000 + A1:2004 + A2:2008 + A12:2003 +
A13:2004 + A14:2005 + A15:2007 + A16:2007

Automatic electrical controls for household and similar
use -- Part 2-9: Particular requirements for temperature
sensing controls



Signature: _____
Date: Jun. 03, 2013



The test report was carried out from the submitted type samples of a product in compliance with the specification of the respective standards. The certificate holder has the right to fix the CE-mark for LVD directive on the product complying with the inspection samples